



Village of Round Lake Community Development

442 N. Cedar Lake Road, Round Lake, IL 60073

Ph. 847-546-0963 Fax 847-546-1872

www.eroundlake.com

LAWN IRRIGATION REQUIREMENTS

PERMIT APPLICATION CHECKLIST

- Complete and sign Building Permit Application including e-mail address.
- Provide two copies of the plat of survey showing location of all sprinkler system components including number of sprinkler heads (also provide number on permit application) and location of heads on plat of survey.
- Copy of plumber's license and a letter of intent including back flow protection method.
- Homeowner's Association approval letter (if applicable).
- Provide copy of contract including scope of work (if applicable).
- Call JULIE at 1-800-892-0123 for location of utilities prior to digging.
- For parkway sprinkler heads: Completed Application for Right of Way License Permit with required drawing that includes sprinkler head locations and signed Terms of License, Waiver and Release of Liability and Agreement to Indemnify.

Permit applications will NOT be accepted without all of the above requirements.

PERMIT FEES

Please refer to the Village of Round Lake Municipal Code 20.56.010.

BOND REQUIREMENTS

A \$250.00 refundable cash bond is required.

PERMIT GUIDELINES

- The state of Illinois requires an irrigation registration card or a plumbing license for every person designing, supervising, installing, servicing, maintaining, operating equipment, or performing labor on a lawn sprinkler system.
- The indoor piping, backflow preventer and final connection to the system must be performed by a licensed plumber.
- A licensed plumber must inspect the system for proper mechanical operation and supply the village with RPZ certification.
- The homeowner and licensed plumber must sign the state registration form.
- The RPZ must be inspected and certified on an annual basis by a licensed Connection Control Device Inspector and the report submitted to the Round Lake Public Works Department.

INSPECTIONS

1. Rough Plumbing (inspection of exposed sprinkler system prior to backfill).
2. Final Plumbing (inspection after the plumbing connections are complete in the basement and the RPZ is in place and tested).